

Určení závad stokových sítí dle kódovacího systému ČSN EN 13508-2 + A1

Kódování závad úseků dle ČSN EN 13508-2+A1								
Úsek	Poloha v podélném směru (staničení) [m]	Kód vady	Charakterizace		Kvantifikace		Poloha na obvodu	
			1	2	1	2	1	2
147528	21.64	BAH					11	
	28.75	BAH					1	
	0.00-35.90	BAF	A	B			12	12
147529	9.98	BBF	A				8	10
	12.34	BBF	A				8	9
	23.07	BCA	E	A	300		9	
	30.14	BBF	B				8	
	0.00-35.70	BAF	A	B			12	12
147530	5.14	BBF	A				4	
	8	BBF	C				9	
	10.55	BBF	C				10	
	20.21	BBF	C				4	
	22.64	BBF	D				3	
	27.77	BBF	C				11	
	30.36	BBF	C				10	
	37.73	BBF	B				1	
	50.33	BBF	D				2	
	0.00-53.40	BAF	A	B			12	12
147531	20.55	BBF	C				8	
	20.55	BAB	A	B	3		9	12
	27.66	BBF	B				3	
	0.00-46.20	BAF	A	B			12	12
147532	0.00-23.70	BAF	A	B			12	12
147533	0.50-1.50	BBE	Z		5		5	
	0.00-31.40	BAF	A	B			12	12
145738	0.00-38.50	BAF	A	B			12	12
147523	11.65	BAG			5		1	
	34.04	BAG			30		2	
	39.02	BAH					10	
	0.00-58.60	BAF	A	B			12	12

Kódování závad v šachtách dle ČSN EN 13508-2 + A1								
Šachta	Výškové umístění [m]	Kód vady	Charakterizace		Kvantifikace		Poloha na obvodu	
			1	2	1	2	1	2
37034		DAQ	Z					
	0.00-2.14	DAF	A	B			12	12
37033		DAQ	Z					
	0.00-2.64	DAF	A	B			12	12
37032		DBF	D				5	
		DAQ	B					
	0.00-2.15	DAF	A	B			12	12
37031		DAQ	G					
	0.00-2.15	DAF	A	B			12	12
37030		DAQ	Z					
	0.00-2.21	DAF	A	B			12	12
37029		DAG			300		7	
		DAQ	B					
	0.00-2.04	DAF	A	B			12	12
37028		DAQ	Z					
	0.00-2.17	DAF	A	B			12	12
37025		DAQ	Z					
	0.00-2.15	DAF	A	B			12	12
37024		DAQ	Z					
	0.00-2.28	DAF	A	B			12	12